

**Project Review Committee  
Section 248 Cases**

<u>Case Number</u>	<u>Date filed</u>	<u>Issue Type</u>	<u>Petitioner / Applicant Name</u>	<u>Municipality</u>	<u>Description</u>	<u>CVRPC Action</u>	<u>Project Status</u>
<a href="#">26-0446-AN</a>	3/11/2026	§ 248(j)	Town of Northfield Electric Department	Northfield	21-day advance submission of Town of Northfield Electric Department, pursuant to 30 V.S.A. §248, for approval to realign a portion of the 3357 subtransmission line in Northfield, VT	Conducted initial review of project (248, 248a, 248i, 248j, 8010). The project relocates where the subtransmission line crosses the railway tracks to the substation away from the river improving the flood resiliency of the line. Propose to submit initial review, emphasizing resilience benefits of the project, to the petitioner. Note the project will be reviewed again once filed and the RPC may submit comments then as well.	New
<a href="#">26-0280-NMR</a>	2/10/2026	§ 8010 (Net-metering)	Green Mountain Power	Montpelier	100 State Street Hospitality, LLC 100.0 kW solar NM in Montpelier	Reviewed project- rooftop so existing preferred site. Further evaluation unnecessary.	Closed CPG Issued 2/25/2026
<a href="#">25-2468-PET (25-0899-AN and 24-0383-AN)</a>	10/10/2025	§ 248	Green Mountain Power	Waitsfield and Fayston	45-day advance submission of Green Mountain Power for a certificate of public good, pursuant to 30 V.S.A. § 248, authorizing to upgrade the Irasville #39 Substation in towns of Fayston, Waitsfield, and Warren. This is the second advance notice filed for this project at this location (see 24-0838-AN). There have been no changes in the design since the previous advance notice filing; however, the construction schedule has changed since the previous filing. 5/6/2025: advance notice filed. 10/10/25 (administratively complete 10/17) petition filed.	Reviewed (memo). 30 Day Period to File Public Comments, Requests to Intervene, and Requests for Hearing (past). CVRPC will monitor proceeding. 12/10/25 GMP responded to first round of discovery questions from ANR (soil disturbance total) and PSD (condition of existing transformer (57yo), replacement rationale for equipment less than 30yo, peak load date correction, coincident peak load combined Irasville #39 & Madbush substations (non-cincident provided), cost of alternatives). 2/11/26 Staff reviewed Comments from AAFA which found the impact to prime agricultural soils to be within the de minimis threshold and therefore not have an undue burden (threshold is two acres; project potential impacts less than 1 acre). <b>2/25/26 Stipulation/MOU/Settlement Agreement ANR and GMP. 3/6/26 DPS filed Comments and 202(f) Determination. 3/19/26 Proposed Findings and Draft CPG.</b>	Draft CPG Proposed. 3/19/26
<a href="#">25-0899-AN</a>	3/22/2024	§ 248	Green Mountain Power	Waitsfield and Fayston	3/22/2024: 45-day advance notice of upcoming petition for Certificate of Public Good to upgrade Irasville #39 Substation at 236 Carroll Road in Waitsfield and Fayston (24-0838-AN). <b>Updated 45-Day Advance Notice 5/6/25. Petition filed (see above)</b>		Petition filed see above.